

Water System Name: Happy Valley Water District		PWS ID No.: 1280220 RE
Collector: Cole Rayner	Date Collected: 01/26/2021	County: Kootenai
Report Results to: Happy Valley Water District Cole Rayner P.O. Box 2306 Hayden, ID 83835		
Phone: (208) 651-7769	Fax:	
E-Mail: Leslie@gemstate-water.com, pwsreports@deq.idaho.gov		

COLIFORM BACTERIA
ANALYSIS REPORT
CONTAMINANT ID# 3100

Type of System:	Public
Type of Sample:	Compliance Sample
Lab Order No.:	2021010416

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com Lab EPA ID No: ID00912
--

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

Sample Number	Sample Type	Sample Location	Time Collected	Chlorine Residual ppm	Original Sample Date	Total Coliform Method: 9223B-PA	E. Coli Method: 9223B-PA
224832	RS-Routine Sample	10304 Meyer Rd	13:30			Absent	Absent

Sample Transportation by (Name):	Cole Rayner	Date/Time:	01/26/2021 14:10	Analyst: GM	Date Analyzed: 01/27/2021
Sample Received by (Name):	JM	Date/Time:	01/26/2021 14:10	Supervisor: Rhena Cooper	
Remarks:				Date Reviewed and Printed: 01/27/21	