Water System Name: PWS ID No.: Arrow Point Community System 1280252 RE Date Collected: Collector: County: 05/09/2023 Kootenai Dean Renninger Report Results to: Arrow Point Community System Leslie Abrams 4502 S. Arrow Point Dr. Harrison, ID 83833 Fax: (208) 667-0745 Phone: (208) 667-0726 E-Mail: Leslie@gemstate-

water.com,pwsreports@deq.idaho.gov,cole@gemstatewater.com,lisa@gemstate-water.com,info@gemstate-

water.com

COLIFORM BACTERIA

ANALYSIS REPORT

CONTAMINANT ID# 3100

Type of System: Public

Type of Sample: Compliance Sample

Lab Order No.: 2023050185

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks. Laboratory Name:

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Lab EPA ID No: ID00912

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

| Sample Number | Sample Type | Sample Location | Time Collected | Chlorine Residual ppm | Original Sample Date | Total Coliform Method: 9223B-PA | E. Coli Method: 9223B-PA |
|------------------|-------------------|-----------------|-------------------|--------------------------|-------------------------|---------------------------------------|--------------------------------|
| 254679 | RS-Routine Sample | Building C | 09:15 | 0.38 | | Absent | Absent |

| Sample Transportation by (Name): | Dean Renninger | Date/Time: | 05/09/2023 10:00 | Analyst: ME | Date Analyzed: 05/10/2023 |
|----------------------------------|----------------|-------------------------------------|------------------|---------------|---------------------------|
| Sample Received by (Name): | JM | Date/Time: | 05/09/2023 10:00 | Supervisor: R | hena Cooper |
| Remarks: | | Date Reviewed and Printed: 05/10/23 | | | |