

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/14/2023	Date Reported: 09/18/2023
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: <b>1280343 PH</b>	PWS Name: <b>Lakeland Meadows</b>
County: Kootenai	

Laboratory Name:  
**Accurate Testing Labs, LLC**  
7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378  
Fax (208) 762 9082  
Web site: www.accuratetesting.com  
E-mail: info@accuratetesting.com

**Order Number: 2023090351**

**INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER**

		<b>Copper</b>	<b>Lead</b>	
Action Level (AL):		1.3 mg/L	0.015 mg/l	
Test Method:		EPA 200.5	EPA 200.5	
Analyst:		WM	WM	
<b>Lab Sample #</b>	<b>Date Collected</b>	<b>Sampling Location</b>	<b>Copper mg/L</b>	<b>Lead mg/L</b>
259810	09/13/2023	24941	0.0054	ND
259811	09/13/2023	5626	0.0070	ND
259812	09/13/2023	5697	0.0026	ND
259813	09/13/2023	6094	0.0130	ND
259814	09/13/2023	25258	0.0070	ND

Lakeland Meadows  
3465 S. Walkers Bay Rd  
Coeur d'Alene, ID 83814



09/18/23

Laboratory Supervisor, Digitally signed by: *Walter*