

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/14/2023	Date Reported: 09/20/2023
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1280157 RE	PWS Name: Rocky Beach Water
County: Kootenai	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2023090352

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

	Copper	Lead		
Action Level (AL):	1.3 mg/L	0.015 mg/l		
Test Method:	EPA 200.5	EPA 200.5		
Analyst:	WM	WM		
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
259815	09/14/2023	6379 Nautical Loop	0.102	0.0041
259816	09/14/2023	30455 Nautical Loop	0.0565	0.0016
259817	09/14/2023	30721 Osprey Pt	0.0575	ND
259818	09/14/2023	30241 Nautical Lop	0.0350	ND

Rocky Beach Water District
P.O. Box 126
Spirit Lake, ID 83869



09/20/23

Laboratory Supervisor, Digitally signed by: *Walter*