

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/14/2023	Date Reported: 09/20/2023
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1280139 PH	PWS Name: Pine Haven MHP
County: Kootenai	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2023090355

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

	Copper	Lead		
Action Level (AL):	1.3 mg/L	0.015 mg/l		
Test Method:	EPA 200.5	EPA 200.5		
Analyst:	WM	WM		
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
259826	09/12/2023	House	0.0089	ND
259827	09/12/2023	Unit V	0.0124	ND

Pine Haven Mobile Park
5725 Hwy 53
Rathdrum, ID 83858



09/20/23

Laboratory Supervisor, Digitally signed by: *Walter*