

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/29/2023	Date Reported: 10/10/2023
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1280092 PH	PWS Name: Hidden Hill LLC
County: Kootenai	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2023090803

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

		Copper	Lead	
Action Level (AL):		1.3 mg/L	0.015 mg/l	
Test Method:		EPA 200.5	EPA 200.5	
Analyst:		WM	WM	
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
260677	09/29/2023	Lot 1	0.0071	0.0049
260678	09/26/2023	Lot 23	0.0388	ND

Hidden Hill LLC

4451 W. Seltice Way
Coeur d'Alene, ID 83814



10/10/23

Laboratory Supervisor, Digitally signed by: *Walter*