

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/28/2023	Date Reported: 10/04/2023
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: <b>1280157 RE</b>	PWS Name: <b>Rocky Beach Water</b>
County: Kootenai	

Laboratory Name:  
**Accurate Testing Labs, LLC**  
7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378  
Fax (208) 762 9082  
Web site: www accuratetesting.com  
E-mail: info@accuratetesting.com

**Order Number: 2023090765**

**INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER**

	<b>Copper</b>	<b>Lead</b>		
Action Level (AL):	1.3 mg/L	0.015 mg/l		
Test Method:	EPA 200.5	EPA 200.5		
Analyst:	WM	WM		
<b>Lab Sample #</b>	<b>Date Collected</b>	<b>Sampling Location</b>	<b>Copper mg/L</b>	<b>Lead mg/L</b>
260608	09/27/2023	Greg Mattison	0.0284	ND

Rocky Beach Water District  
P.O. Box 126  
Spirit Lake, ID 83869



10/04/23

Laboratory Supervisor, Digitally signed by: *Walter*