

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www.accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2024040373**

Page: 1 of 1

Bitterroot Water Company
P.O. BOX 2306
Hayden , ID 83835

Project: PWS#1280260

Date Received: 04/17/2024 12:35

Sample: **4** Matrix: Drinking Water
Location: D0098512 Well #3 D/T Collected: 04/17/2024 12:00
Sample Type: Plant Tap Collected by: Thomas Mullen

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
Alkalinity (CaCO3)	140	mg/L	SM 2320B	0.05	04/18/24	WM
Calcium	40.1	mg/L	EPA 200.7	0.022	04/18/24	WM
Iron	1.4	mg/L	EPA 200.7	0.0078	04/18/24	WM
Langelier Index	0.15		Misc.		04/18/24	WM
Manganese	0.0085	mg/L	EPA 200.7	0.0006	04/18/24	WM
pH	7.90	pH Units	EPA 150.1		04/17/24	WM
Total Dissolved Solids	171	mg/L	SM 2540C	1	04/18/24	RH

If the RESULT is 'ND' (Not Detected) or 'Absent', that means the concentration is less than the PQL (Practical Quantitation Limit for this method).

Comments:



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 05/03/24