

Lab EPA ID No.: ID00912	Lab Sample#: 266908
Date Received: 04/17/2024	Date Reported by Lab: 05/03/24
Compliance or Replacement Sample: Compliance	
Date Collected: 04/17/2024	Time Collected: 12:00
Sample Type: Plant Tap	
PWS No.: 1280260 RE	PWS Name: Bitterroot Water Company
Sampling Location: D0098512 Well #3	Tag#
Collector: Thomas Mullen	Phone: (208) 651-7769

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Lab Order No.: 2024040373 1

Public Drinking Water System INORGANIC CHEMICAL (IOC) ANALYSIS REPORT:

Phase II								Phase V							
FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst	FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst
1010	Barium	0.025	2.0	0.000	EPA 200.5	04/22/24	WM	1036	Nickel	0.0008	0.10	0.000	EPA 200.5	04/22/24	WM
1015	Cadmium	ND	0.000	0.000	EPA 200.5	04/22/24	WM	1074	Antimony	ND	0.006	0.002	EPA 200.5	04/22/24	WM
1020	Chromium	ND	0.10	0.000	EPA 200.5	04/22/24	WM	1075	Beryllium	ND	0.004	0.000	EPA 200.5	04/22/24	WM
1035	Mercury	ND	0.002	0.000	EPA 245.1	04/22/24	WM	1085	Thallium	ND	0.002	0.000	EPA 200.9	04/22/24	WM
1038	NO2/NO3	0.598	10.0	0.047	EPA 300.0	04/18/24	WM	<i>Other IOCs</i>							
1040	Nitrate-N	0.598	10.0	0.024	EPA 300.0	04/18/24	WM	1005	Arsenic	0.0019	0.010	0.001	EPA 200.5	04/22/24	WM
1041	Nitrite-N	ND	1	0.023	EPA 300.0	04/18/24	WM	1025	Fluoride	0.082	4.0	0.009	EPA 300.0	04/18/24	WM
1045	Selenium	ND	0.050	0.001	EPA 200.5	04/22/24	WM	1052	Sodium	3.88	500	0.01	EPA 200.7	05/03/24	WM
1024	Cyanide														
<i>Secondary IOCs (optional)</i>															
1002	Aluminum							1055	Sulfate	5.69	250	0.006	EPA 300.0	04/18/24	WM
1003	Ammonia							1095	Zinc						
1016	Calcium							1905	Color						
1017	Chloride							1915	Hardness						
1022	Copper							1920	Odor						
1027	Hyd. Sulfide							1925	pH						
1028	Iron							1926	Conductivity						
1031	Magnesium							1927	Alkalinity						
1032	Manganese							1930	Diss. Solids						
1042	Postassium							1997	Langlier Indx						
1049	Silica SiO2							2905	Surfactants						
1050	Silver							1030	Lead						

*Reported in mg/L unless otherwise noted, units differ for secondary MCLs depending on contaminant
ND = Not detected within sensitivity of instrument
Empty = No analysis performed for this contaminant
MDL = Method detection limit
MCL - Maximum Contaminant Level

Comments:



05/03/24

Bitterroot Water Company

Laboratory Supervisor

P.O. BOX 2306
Hayden, ID 83835

Digitally signed by:
Walter Mueller