

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www.accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2024040373**

Page: 1 of 2

Bitterroot Water Company
P.O. BOX 2306
Hayden , ID 83835

Project: SOC Report PWS#1280260

Date Received: 04/17/2024 12:35

Sample: **3**
Location: D0098512 Well #3
Sample Type: Plant Tap

Matrix: Drinking Water
D/T Collected: 04/17/2024 12:00
Collected by: Thomas Mullen

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
Ethylene Dibromide (EDB)	ND	ug/L	EPA 504.1	0.01	04/25/24	ANA
1,2-Dibromo-3-chloropropane (DBCP)	ND	ug/L	EPA 504.1	0.02	04/25/24	ANA
Alachlor	ND	ug/L	EPA 525.2	0.2	04/25/24	ANA
Atrazine	ND	ug/L	EPA 525.2	0.1	04/25/24	ANA
Simazine	ND	ug/L	EPA 525.2	0.07	04/25/24	ANA
Chlordane (Total)	ND	ug/L	EPA 505	0.2	05/08/24	ANA
Endrin	ND	ug/L	EPA 505	0.01	05/08/24	ANA
Heptachlor	ND	ug/L	EPA 505	0.04	05/08/24	ANA
Heptachlor Epoxide	ND	ug/L	EPA 505	0.02	05/08/24	ANA
Hexachlorobenzene	ND	ug/L	EPA 525.2	0.1	04/25/24	ANA
Hexachlorocyclopentadiene	ND	ug/L	EPA 525.2	0.1	04/25/24	ANA
Lindane (BHC gamma)	ND	ug/L	EPA 505	0.02	05/08/24	ANA
Methoxychlor	ND	ug/L	EPA 505	0.1	05/08/24	ANA
Toxaphene	ND	ug/L	EPA 505	1	05/08/24	ANA
PCB (As Total Arochlors)	ND	ug/L	EPA 505	0.5	05/08/24	ANA
Benzo(a)pyrene	ND	ug/L	EPA 525.2	0.02	04/25/24	ANA
bis(2-ethylhexyl)adipate	ND	ug/L	EPA 525.2	0.6	04/25/24	ANA
bis-2(Ethylhexyl)phthalate	ND	ug/L	EPA 525.2	0.6	04/25/24	ANA
Carbofuran	ND	ug/L	EPA 531.2	0.9	04/26/24	ANA
Oxamyl	ND	ug/L	EPA 531.2	2	04/26/24	ANA
Glyphosate	ND	ug/L	EPA 547	5	04/24/24	ANA
Endothall	ND	ug/L	EPA 548.1	9	04/26/24	ANA
Diquat	ND	ug/L	EPA 549.2	0.4	04/26/24	ANA
2,4-D	ND	ug/L	EPA 515.4	0.1	04/25/24	ANA

Comments:

[Sub Lab: Anatek Labs](#)



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 05/14/24

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2024040373**

Page: 2 of 2

2,4,5-TP (Silvex)	ND	ug/L	EPA 515.4	0.2	04/25/24	ANA
Pentachlorophenol	ND	ug/L	EPA 515.4	0.04	04/25/24	ANA
Dalapon	ND	ug/L	EPA 515.4	1	04/25/24	ANA
Dinoseb	ND	ug/L	EPA 515.4	0.2	04/25/24	ANA
Picloram	ND	ug/L	EPA 515.4	0.1	04/25/24	ANA

If the RESULT is 'ND' (Not Detected) or 'Absent', that means the concentration is less than the PQL (Practical Quantitation Limit for this method).

Comments:

[Sub Lab: Anatek Labs](#)



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 05/14/24