

Water System Name: Pelican Point Water		PWS ID No.: 66800L
Collector: Cole Rayner	Date Collected: 04/29/2024	County: Grant
Report Results to: Pelican Point Water Leslie Rayner P.O. Box 3388 Coeur d'Alene, ID 83816		
Phone: (208) 651-7769	Fax:	
E-Mail: Leslie@gemstate-water.com,cole@gemstate-water.com,lisa@gemstate-water.com		

COLIFORM BACTERIA
ANALYSIS REPORT
CONTAMINANT ID# 3100

Type of System:	Public
Type of Sample:	Non-Compliance Sample
Lab Order No.:	2024040578

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com Lab EPA ID No: ID00912
--

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

Sample Number	Sample Type	Sample Location	Time Collected	Chlorine Residual ppm	Original Sample Date	Total Coliform Method: 9223B-PA	E. Coli Method: 9223B-PA
267307	C-Construction	Location 1	14:45	1.25		Absent	Absent
267308	C-Construction	Location 2	15:15	1.18		Absent	Absent

Sample Transportation by (Name):	Cole Rayner	Date/Time:	04/30/2024 07:10	Analyst: RH	Date Analyzed: 05/01/2024
Sample Received by (Name):	JM	Date/Time:	04/30/2024 07:10	Supervisor: Rhena Cooper	
Remarks:				Date Reviewed and Printed: 05/01/24	