

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www.accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2024040373**

Page: 1 of 2

Bitterroot Water Company
P.O. BOX 2306
Hayden, ID 83835

Project: VOC Report PWS#1280260

Date Received: 04/17/2024 12:35

Sample: **2**
Location: D0098512 Well #3
Sample Type: Plant Tap

Matrix: Drinking Water
D/T Collected: 04/17/2024 12:00
Collected by: Thomas Mullen

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
1,2,4-Trichlorobenzene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
cis-1,2-dichloroethylene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Total Trihalomethanes	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Chloroform	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Bromoform	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Bromodichloromethane	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Dibromochloromethane	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Xylenes	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Dichloromethane	ND	ug/L	EPA 524.2	0.5	04/22/24	ANA
Vinyl Chloride	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
1,1-Dichloroethylene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Trans-1,2-Dichloroethylene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
1,2-Dichloroethane	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
1,1,1-Trichloroethane	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Carbon Tetrachloride	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
1,2-Dichloropropane	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Trichloroethylene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Tetrachloroethylene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Monochlorobenzene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Benzene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Toluene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Ethylbenzene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
Styrene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
o-Dichlorobenzene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA

Comments:

[Sub Lab: Anatek Labs](#)



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 05/14/24

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2024040373**

Page: 2 of 2

p-Dichlorobenzene	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA
1,1,2-Trichloroethane	ND	ug/L	EPA 524.3	0.5	04/22/24	ANA

If the RESULT is 'ND' (Not Detected) or 'Absent', that means the concentration is less than the PQL (Practical Quantitation Limit for this method).

Comments:

[Sub Lab: Anatek Labs](#)



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 05/14/24