

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 07/10/2024	Date Reported: 07/16/2024
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: <b>1280259 HD1</b>	PWS Name: <b>Lynnwood Estates</b>
County: Kootenai	

Laboratory Name:  
**Accurate Testing Labs, LLC**  
7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378  
Fax (208) 762 9082  
Web site: www accuratetesting.com  
E-mail: info@accuratetesting.com

**Order Number: 2024070206**

**INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER**

	<b>Copper</b>	<b>Lead</b>		
Action Level (AL):	1.3 mg/L	0.015 mg/l		
Test Method:	EPA 200.5	EPA 200.5		
Analyst:	WM	WM		
<b>Lab Sample #</b>	<b>Date Collected</b>	<b>Sampling Location</b>	<b>Copper mg/L</b>	<b>Lead mg/L</b>
270081	07/09/2024	32883 N Roberts	0.0132	ND
270082	07/09/2024	32599 N Roberts	0.0293	0.0014
270083	07/09/2024	6912 N Jenson	0.0112	ND
270084	07/09/2024	32596 N Lumia	0.0106	ND
270085	07/09/2024	6540 E Williams Ln	0.0105	ND

Lynnwood Estates

P.O. Box 3388  
Coeur d'Alene, ID 83816



07/16/24

Laboratory Supervisor, Digitally signed by: *Walter*