

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 07/18/2024	Date Reported: 07/22/2024
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1400039 RE	PWS Name: Murray Water Works
County: Shoshone	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2024070458

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

		Copper	Lead	
Action Level (AL):		1.3 mg/L	0.015 mg/l	
Test Method:		EPA 200.5	EPA 200.5	
Analyst:		WM	WM	
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
270537	07/17/2024	Hele 6518 Prichard Street	0.0267	ND
270538	07/17/2024	Hele 6400 Prichard Street	0.0124	0.0014
270539	07/16/2024	Shull 6186 Prichard Street	0.0020	ND
270540	07/17/2024	Hendrickson 6173 Prichard Street	0.0027	ND
270541	07/17/2024	Hele 6439 Prichard Street	0.114	ND

Murray Water Works

P.O. Box 920
Rathdrum, ID 83858



07/22/24

Laboratory Supervisor, Digitally signed by: *Walter*