

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/25/2024	Date Reported: 10/10/2024
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1280252 RE	PWS Name: Arrow Point Community System
County: Kootenai	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2024090672

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

	Copper	Lead		
Action Level (AL):	1.3 mg/L	0.015 mg/l		
Test Method:	EPA 200.5	EPA 200.5		
Analyst:	WM	WM		
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
273623	09/25/2024	Building C	0.0428	ND
273624	09/25/2024	Building B	0.146	ND
273625	09/25/2024	Building A	0.128	ND
273626	09/25/2024	Pool House	0.0720	ND
273627	09/25/2024	Office	0.0076	ND

Arrow Point Community System
4502 S. Arrow Point Dr.
Harrison, ID 83833



10/10/24

Laboratory Supervisor, Digitally signed by: *Walter*