

Water System Name: River Terrace MHP		PWS ID No.: 1090126 RE
Collector: Bryan Brewer	Date Collected: 06/02/2025	County: Bonner
Report Results to: River Terrace MHP Leslie Abrams P.O. Box 3388 Coeur d'Alene, ID 83816		
Phone: (208) 651-7769	Fax:	
E-Mail: leslie@gemstate-water.com,pwsreports@deq.idaho.gov,cole@gemstate-water.com,info@gemstate-water.com		

COLIFORM BACTERIA

ANALYSIS REPORT

CONTAMINANT ID# 3100

Type of System:	Public
Type of Sample:	Compliance Sample
Lab Order No.:	2025060024

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com Lab EPA ID No: ID00912
--

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

Sample Number	Sample Type	Sample Location	Time Collected	Chlorine Residual ppm	Original Sample Date	Total Coliform Method: 9223B-PA	E. Coli Method: 9223B-PA
282509	RS-Routine Sample	Lot O	09:35			Absent	Absent

Sample Transportation by (Name):	Bryan Brewer	Date/Time:	06/03/2025 07:44	Analyst: LN	Date Analyzed: 06/04/2025
Sample Received by (Name):	JM	Date/Time:	06/03/2025 07:44	Supervisor: Rhena Cooper	
Remarks:				Date Reviewed and Printed: 06/04/25	